

Elektr ta'minotining shartnomasiga

5-ilova

**Energiya (aktiv, reaktiv) sarfi bo'yicha
HISOBOT**

20 ____ yil _____ oy bo'yicha

Ko'rsatkichlar qayd etilgan sana «_____» 20 ____ yil.

Ulangan joy nomi, hisobga olish priborining zavod raqami, hisobga olish turi (aktiv, reaktiv)	Hisob-kitob koeffitsienti		Hisobga olish pribori ko'rsatgichlari		Hisobga olish pribori kursatkichlarining farqi	Sarf kVt.s., kVAr.s.	Tabaqalashtirilgan tarif bo'yicha sarf kVt.s.					
	tok transformatorining (TT)	kuchlanish transformatorining (KT)	umu-miy	boshlang'ich	oxirgi		Erta-labki	Kun	Kechki	Tun		
							tig'iz vaqt	soat 6-9	soat 9-17	soat 17-22	soat 22-24	soat 0-6
1	2	3	4	5	6	7	8	9	10	11	12	13
124200534788	400/5		80	1	43	42	3360					
124200534789	400/5		80	1	5	4	320					
124200534784	200/5		40	1	115	114	4560					
124200534787	300/5		60	1	27	26	1560					
124200534785	600/5		120	1	26	25	3000					
Jami												

Izoh: $7_{\text{ustun}} = 6_{\text{ustun}} - 5_{\text{ustun}}$, tabaqalashtirilgan hisob uchun nazorat raqami $8_{\text{ustun}} = 7_{\text{ustun}} * 4_{\text{ustun}}$,
 $8_{\text{ustun}} = 9_{\text{ustun}} + 10_{\text{ustun}} + 11_{\text{ustun}} + 12_{\text{ustun}} + \text{gr} 13_{\text{ustun}}$;

Iste'molchi rahbari

M.O.

T.M.Tilapov

F.I.SH.imzosi

Ta'minotchi korxona energetigi

F. I. SH.imzosi

